

Vport ad hoc SOA D0.9 comment resolution

October 2007

Fred Schindler
Cisco Systems

Andrew Smith
Andy Weitzner
Anoop Vetteth
Christen Beia
Clay Stanford
Daniel Feldman
David Law
Ferdinando Lari
Fred Schindler
Jeff Heath
John Jetzt
Joseph Maggion
Marius Vladan
Martin Patoka
Matthew Landry
Michael Altmann
Peter Johnson
Riccardo Russo
Thong Huynh
Wael Diab
Yair Darshan

Power Integration
Marvel
Cisco Systems
ST Microelectronics
Linear Technology
Microsemi
3COM
ST Microelectronics
Cisco Systems
Linear Technology
Avaya
Broadcom
AMI
Texas Instruments
Silicon Labs
Akros Silicon
SIFOS
ST Microelectronics
Maxim
Broadcom
Microsemi

Dan Dove
Frank Yung
Fred Schindler
Geoff Thompson
Gianluca Sanità
Helen Kastner
Hugh Barrass
James Blanc
Jean F.
Jean Picard
Keith Hopwood
Ken Bennett
Larry Shorthill
Michael Altmann
Pavlick Rimboim
Ramesh Sastry
Raul Lozano
Sajol Ghoshal
Sharon Dagon
Steve M
Taufique Ahmed
Thong Huynh
Thuyen Dinh
Tim Parker
Val Rybinski

HP Procurve Networking
SystemX
Cisco Systems
Nortel Networks
Nokia Siemens Network
Cisco Systems
Cisco Systems
Independ. VC investigation R & D
AMI
Texas Instruments
Phihong
SIFOS
NXP
Akros Silicon
Microsemi
Cisco Systems
Pulse
Akros Silicon
AMI
AMI
Akros Silicon, HP
Maxim
Pulse
Nortel Networks
Siemon


Two ad hocs with an average attendance of 17 people since the last IEEE meeting.
People that attended since the last IEEE meeting are shown in **bold**.

Agenda

- **Recommendations for the SOA-comment bucket.**
- **Next step.**

D0.9 Comments 178, 137

- Page 25, line 50
- “A PSE in the power on state may remove power from the PI when the PI voltage no longer meets the Vport specification.”
- Add San Francisco due to a Vport ad hoc motion
All present; Y: 30 N: 0 A: 4
802.3; Y: 19 N: 0 A: 0 => PASS



Worst-case

$R_{ch} = 0$

V_{pse} goes from 50 to 57 V

V_{pass} goes from 0 to 7 V

$I_{PD} = 400/350 \times P_{port}/V_{port}$

Recommend resolution to 178, 137

- **Leave text as is.**
- **All present; Y: 18 N: 0 A: 0**
- **Peter withdraws comment.**
- **Clay withdraws comment.**

D0.9 Comments 11 and 111

- **Page 28, Line 39**
- **“If a short circuit condition is detected, power removal from the PI shall begin within TLIM and be complete by TOFF, as specified in Table 33-5. See Figure 33C.4 [p90]and Figure 33C.6[p92].”**
- **This is legacy text.**
- **Figure 33C.4 [p90] should be replaced by Figure 33-9a [p28] for power-on operation.**

Recommend Resolution to 11, 111

- **Combine sections 33.2.8.8 and 33.2.8.9.**
- **TLIM defined by the SOA curve Figure 33-9a.**
- **The system needs to operate below the SOA curve.**
- **Expect to have SOA, PD, and PSE requirements on Figure 33-9a.**
- **All present; Y: 18 N: 0 A: 0**
- **Matt and Yair accept this resolution.**

Comments 78, 96

- **Page 27, Line 43**
- **“Power shall be removed immediately from the PI of a type 2 PSE if the PI current exceeds the Safe Operating Area (SOA) upper bound template in Figure 33-9a.”**

Recommended Resolution 78, 96

- “Power shall be removed ~~immediately~~ from the PI of a type 2 PSE **before** ~~if~~ the PI current exceeds the Safe Operating Area (SOA) upper bound template in Figure 33-9a.”
- All present; Y: 18 N: 0 A: 0
- Yair accepts this resolution.
- Dan ??? this resolution.

Recommended Resolution 122

- **Accept remedy.**
- **All present; Y: 18 N: 0 A: 0**

CI 33 SC 2.8.8 P27 L49 # 122
Darshan, Yair Microsemi Corporation

Comment Type TR Comment Status X soa

Change the Fusing equation in a way that reflect all its parameters.
See "Fusing equation: how it was derived in 802.3af" presentation for September 2007 for more details.

SuggestedRemedy
Change from $I=(0.025/t)^{0.5}$
To: $I_{port}=(K/t)^{0.5}$
Where
 I_{port} is the current at the PI
 t is the duration that the PI sources I_{port}
 K is a 25mJoule energy limitation of the port current when it is not in steady state normal operation.

Yair accepts this resolution.

Comment 185

CI 33 SC 2.8.8 P27 L33 # 185
Schindler, Fred Cisco Systems

Comment Type TR Comment Status X soa

This section needs to be modified in order to permit PSE to reach current levels just below the SOA described in figure 33-9a.

SuggestedRemedy

If a PSE provides current that meets system safe operating (SOA) requirements, IEC 60950, and PD minimum power needs, then safety and interoperability are met with fewer design requirements imposed. Within the region between PD current needs and SOA current limits, a PSE system selects the design (current limit, current cut-off, and duration) that meets its markets needs. See Vport ad hoc current limit presentations for the latest proposed system current vs time limits.

Suggested remedy:
Type-1 PSE can power as described in this section.

Add, Type-2 PSEs
Remove the requirement to remove power within TLIM, and require that the PSE meet the SOA limits.
Remove the sentence "Measurement to be taken after 1 ms to ignore initial transients."

**This comment is related to comments/solutions of 78, 96, 11, 111.
i.e., TLIM is defined by the SOA curve in Figure 33-9a.**

Recommend Resolution 185

- Replace “within TLIM” with a reference to Figure 33-9a SOA and its related text for guidance.
- Figure 33-9a is applicable to type 1 and type 2 PSEs.
- Strike text as follows
~~e) Measurement to be taken after 1ms to ignore initial transients.~~
- All present; Y: 15 N: 0 A: 0
- Fred Accepts this resolution.

Note section 33.2.8.8 and 33.2.8.9 text is being reworked due to the resolution for comments 11 and 111.

Comment 186

CI 33 SC 2.8.6 P27 L11 # 186
Schindler, Fred Cisco Systems

Comment Type TR *Comment Status* X soa

The specification requires that a PSE remove power based on maximum ICUT and T_{ovld} thresholds. This does not ensure interoperability or meet the safety specifications, and therefore, forces a design requirement.

Suggested Remedy

Allow the existing requirement or figure 33-9a SOA requirements to specify what is required for compliance.

**This comment is related to comments/solutions of 78, 96, 11, 111.
i.e., TLIM is defined by the SOA curve in Figure 33-9a.**

Recommend Resolution 186

- Correct text as follows:
- “If I_{port} in Table 33-5 exceeds I_{CUT} for longer than T_{ovld} , the PSE ~~shall~~ **may** remove power from the PI.”
- FYI: The requirement to remain below the SOA curve is met by I_{LIM} requirements.
- FYI: The PSE will provide I_{LIM} for at least T_{LIM} .
- All present; Y: 15 N: 0 A: 0
- Fred accepts this resolution.

Assume that when text says PSE this implies type 1 and type 2.

Comment 28

- Page 27, line 43
- “Power shall be removed ~~immediately~~ from the PI of a **type 2** PSE **before** ~~if~~ the PI current exceeds the Safe Operating Area (SOA) upper bound template in Figure 33-9a.” *
- **The comment recommends striking “type 2.”**

* Adapted from comments 78 and 96 resolution.

Comment 28

CI 33 SC 2.8.8

P27

L43

28

LANDRY, MATTHEW

SILICON LABORATO

Comment Type **TR**

Comment Status **X**

soa

Is there any reason not to make SOA curve applicable to Type 1 PSEs as well as Type 2 PSEs? All safety and existing performance studies obviously made use of Type 1 equipment. Further, the SOA curve is well outside of the ILIM max defined for Type 1, therefore it should be impossible for a compliant Type 1 device to violate this new SOA requirement.

SuggestedRemedy

Strike "Type 2"

Recommend Resolution to 28

- “Power shall be removed ~~immediately~~ from the PI of a ~~type 2~~ PSE **before** if the PI current exceeds the Safe Operating Area (SOA) upper bound template in Figure 33-9a.” *
- **Accept Remedy; strike type 2**
- **All present; Y: 15 N: 0 A: 0**
- **Matt accepts this resolution.**

* Adapted from comments 78 and 96 resolution.

Comment 23

CI 33 SC 2.8.8 P28 L32 # 23

LANDRY, MATTHEW SILICON LABORATO

Comment Type T Comment Status X soa

Figure 33-9a title does not specify which PSE Type to which is applies, but the SOA curve applies only to Type 2 PSEs.

SuggestedRemedy
Replace title with:

'Type 2 PSE PI Safe Operating Area'

Proposed Response *Response Status* W

see 28
someone also commented that it could apply to type 1 also (Law?)

A type 2 PSE may power a type 1 PD.

**This was created for a type 2 PSE.
However, the SOA curve may be used for type 1 PSEs and still provide interoperation and IEC 60950 requirements—see comments 28, 185, 186.**

Recommended Resolution 23

- **Leave Figure 33-9a as is.**
- **The SOA is valid for any PSE.**
- **We may need to add text referencing types when the PD current limits and the PSE current requirements are added.**
- **Matt withdraws comment.**
- **All present; Y: 15 N: 0 A: 0**

Next Step

- **Is the PD a constant power load?**
- **Review PD Current Limits.**
- **PSE Current Requirements.**
- **Motion on PSE Current Requirements.**